




Tubes Arrangement ;
 4 x 12 Passes
 4 x blind tubes
 Stützen Preparation = 15 mm



ITEM CODE	UNITS NAME	PAINTING
704EM-AX0000006C	BRC 10.1EJ	Wet Paint RAL 5000
704EM-AX0000007C	BRC 10.2EJ	Wet Paint RAL 9005
704EM-AX0000008C	BRC 10.3EJ	Wet Paint RAL 6033
704EM-AX0000009C	BRC 10.4EJ	Wet Paint RAL 7035
704EM-AX0000010C	BRC 10.5EJ	Powder Coating - Green

Pressure test	35 bar
Delivered unit	Without air pressure, use plastic cap/rubber cap
Type Shield	Version A (Normal size)
Painting	acc. to table
Refrigerant	R22
Packing type	PaLlet (P)
General Tolerance	DIN ISO 2768-v, DIN EN ISO 13920-D

TECHNICAL DATA										
Coil Type	E/4/13/2.4/1040/AXS/2				Fin's material	Alu, t 0.15 mm				
Tubes	Cu, Ripple X, 3/8" x 0.28 mm				Stirnblech	Galv. steel,t 1.25 mm				
Tube Pitch	50 x 25 mm				Ventilatoreblech	Galv. steel,t 1.25 mm				
Finspacing	2.4				Bodenblech	Galv. steel,t 2.0 mm				
Circuits	No of Lines	No of Passes	Header Inlet		Header outlet		Vol of tubes (liter)	exch. surface (m ²)	weight Empty (kg)	weight Operation (kg)
			φ (mm)	Tube In φ (mm)	φ (mm)	Tube out φ (mm)				
A	4	12	28x15	I.D. 22.3	22x10	I.D. 16.3	4.4	54.4	ca. 29.2	-

SCALE:		CUSTOMER:	
POS.		-	
QUANTITY:		-	
DESCRIPTION :			
Condenser; BRC 10 (E)			
BAT E/4/13/2.4/1040/AXS/2			
1	Coil type change to E/4/13/2.4/1040/AXS	17/06/11	PR
POS	CHANGES	DATE	NAME
basetec		DATE	NAME
basetec products & solutions GmbH		DRAWN	DATE
Dornier straÙe 4, 82178 Puchheim		REVIEW	DATE
		2/23/2007	PRI
		6/17/2011	PR
DRAWING NO :		REVISION:	
7-3-060-04483.dft		Page: 1/1	
/priyadi/6/17/2011		ORDER NO :	

FOR APPROVAL