



DETAIL A

ITEM CODE	UNIT'S NAME	PAINTING
704EM-AX0000021C	BRC 13.1(E)	Wet Paint RAL 5000
704EM-AX0000022C	BRC 13.2(E)	Wet Paint RAL 9005
704EM-AX0000023C	BRC 13.3(E)	Wet Paint RAL 6033
704EM-AX0000024C	BRC 13.4(E)	Wet Paint RAL 7035
704EM-AX0000025C	BRC 13.5(E)	Powder Coating - Green

Pressure test	35 bar
Delivered unit	Without air pressure, use plastic cap/rubber cap
Type Shield	Version A (Normal size)
Painting	acc. to table
Refrigerant	R22
Packing type	Pallet (P)
General Tolerance	DIN ISO 2768-v, DIN EN ISO 13920-D



TECHNICAL DATA

Coil Type	E/4/18/2.40/1490/AXS/2	Fin's material	Alu, t 0.15 mm							
Tubes	Cu, Ripple X, 3/8" x 0.28 mm	Stirnblech	Galv. steel, t 1.25 mm							
Tube Pitch	50 x 25 mm	Ventilatorblech	Galv. steel, t 1.25 mm							
Finspacing	2.4 mm	Bodenblech	Galv. steel, t 2.0 mm							
Circuits	No of Lines	No of Passes	Header Inlet		Header outlet		Vol. of tubes (liter)	exch. surface (m ²)	weight Empty (kg)	weight Operation (kg)
			φ (mm)	Tube In φ (mm)	φ (mm)	Tube out φ (mm)				
A	7	10	35x15	I.D. 28.3	28x15	I.D. 22.3	8.7	107.9	ca. 49.8	-

POS	CHANGES	DATE	NAME	SCALE	CUSTOMER :
				QUANTITY :	-
				DESCRIPTION :	Condenser; BRC 13 (E) BAT E/4/18/2.40/1490/AXS/2
				DRAWING NO :	7-3-060-04488.dft
				REVISION :	0
				ORDER NO :	

basetec
products + solutions

basetec products & solutions GmbH
Dornierstraße 4, 82178 Puchheim

DRAWN	DATE	NAME
REVIEW	4/27/2011	PRI
	4/27/2011	PR

DRAWING NO :	7-3-060-04488.dft	Page: 1/1
REVISION :	0	

FOR APPROVAL