## ebm-papst Mulfingen GmbH & Co. KG

Bachmühle 2 D-74673 Mulfingen Phone +49 (0) 7938 81-0 Fax +49 (0) 7938 81-110 info1@de.ebmpapst.com www.ebmpapst.com

## CONTENTS

## 1. SAFETY REGULATIONS AND INFORMATION

2. INTENDED USE	
1.12 Disposal	
1.11 Storage	
1.10 Transport	
1.9 Hot surface	
1.8 Emissions	
1.7 Mechanical movement	
1.6 Electromagnetic radiation	
1.5 Safety and protective features	
1.4 Voltage	
1.3 Basic safety rules	
1.2 Staff qualifications	
1.1 Hazard levels for warnings	

## 3. TECHNICAL DATA

5.2 Safety inspection

	4
3.1 Product drawing	4
3.2 Nominal data	5
3.3 Technical description	5
3.4 Mounting data	5
3.5 Transport and storage conditions	5
4. CONNECTION AND STARTUP	6
4.1 Mechanical connection	6
4.2 Electrical connection	6
4.3 Connection in terminal box	6
4.4 Connection diagram	8
4.5 Opening additional cable glands	9
4.6 Checking connections	9
4.7 Switching on the device	9
4.8 Switching off the device	9
5. MAINTENANCE, MALFUNCTIONS, POSSIBLE CAUSES AND REMEDIES	9
5.1 Cleaning	10

## **1. SAFETY REGULATIONS AND INFORMATION**

Read these operating instructions carefully before starting work on the device. Observe the following warnings to prevent malfunctions or danger to persons.

These operating instructions are to be regarded as part of the device. The device is only to be sold or passed on together with the operating instructions.

These operating instructions may be duplicated and distributed to inform about potential dangers and their prevention.

## 1.1 Hazard levels for warnings

These operating instructions use the following hazard levels to indicate potentially hazardous situations and important safety regulations:



1

1

1

1

2

2

2

2 2

2

2

2

3

A

10

#### DANGER

Indicates an imminently hazardous situation which will result in death or serious injury if the specified actions are not taken. Compliance with the instructions is imperative.

### WARNING

Indicates a potentially hazardous situation which can result in death or serious injury if the specified actions are not taken. Exercise extreme caution while working.

### CAUTION

Indicates a potentially hazardous situation which can result in minor or moderate injury or damage to property if the specified actions are not taken.

## NOTE

A potentially harmful situation can occur and, if not avoided, can lead to property damage.

## 1.2 Staff qualifications

The device may only be transported, unpacked, installed, operated, maintained and otherwise used by suitably qualified, trained and authorized technical staff.

Only authorized specialists are permitted to install the device, to carry out a test run and to perform work on the electrical installation.

## 1.3 Basic safety rules

The safety hazards associated with the device must be assessed again following installation in the final product.

Note the following when working on the device:

⇒ Do not perform any modifications, additions or conversions on the device without the approval of ebm-papst.

### 1.4 Voltage

- Check the device's electrical equipment at regular intervals; see Chapter 5.2 Safety inspection.
- Replace loose connections and defective cables immediately.



## DANGER

Electrically charged device

Risk of electric shock

→ When working on an electrically charged device, stand on a rubber mat.

### WARNING

Live terminals and connections even with device switched off Electric shock





→ Wait five minutes after disconnecting the voltage at all poles before opening the device.

#### CAUTION

In the event of a fault, the rotor and the impeller will be energized

The rotor and the impeller have basic insulation.

 $\rightarrow$  Do not touch the rotor and impeller once installed.

#### CAUTION

# The motor restarts automatically when operating voltage is applied, e.g. after a power failure.

Risk of injury

- $\rightarrow$  Keep out of the device's danger zone.
- → When working on the device, switch off the line voltage and ensure that it cannot be switched back on.
- $\rightarrow$  Wait until the device comes to a stop.

#### 1.5 Safety and protective features



#### DANGER Protective device missing and protective device not functioning

Without a protective device there is a risk of serious injury, for instance if the hands reach or are sucked into the device during operation.

- → Operate the device only with a fixed protective device and guard grille.# The fixed protective device must be able to withstand the kinetic energy of a fan blade that becomes detached at maximum speed. There must not be any gaps which it is possible to reach into with the fingers, for example.
- → The device is a built-in component. As the operator, you are responsible for ensuring that the device is secured adequately.
- → Stop the device immediately if you notice a missing or ineffective protective device.

#### 1.6 Electromagnetic radiation

Interference from electromagnetic radiation is possible, e.g. in conjunction with open- and closed-loop control devices.

If impermissible radiation levels occur following installation, appropriate shielding measures have to be taken by the user.

#### NOTE

## Electrical or electromagnetic interference after installing the device in customer equipment.

 $\rightarrow$  Verify that the entire setup is EMC-compliant.

#### 1.7 Mechanical movement



#### DANGER Rotating device

Risk of injury to body parts coming into contact with the rotor or the impeller.

- $\rightarrow$  Secure the device against accidental contact.
- → Before working on the system/machine, wait until all parts have come to a standstill.

#### WARNING

#### **Rotating device**

Long hair and dangling items of clothing, jewelry and the like can become entangled and be pulled into the device. Injuries can result. → Do not wear any loose-fitting or dangling clothing or jewelry while working on rotating parts.#Protect long hair with a cap.

#### 1.8 Emissions

#### WARNING

#### Depending on the installation and operating conditions, the sound pressure level may exceed 70 dB(A). Risk of noise-induced hearing loss

- $\rightarrow$  Take appropriate technical safety measures.
- → Protect operating personnel with appropriate safety equipment such as hearing protection.
- $\rightarrow$  Also observe the requirements of local agencies.

## 1.9 Hot surface

CAUTION



#### High temperature on motor housing Risk of burns

→ Ensure sufficient protection against accidental contact.

#### 1.10 Transport

#### NOTE

#### Transporting the device

- $\rightarrow$  Transport the device in its original packaging only.
- $\rightarrow$  Secure the device so it cannot slip, e.g. by using a lashing strip.

#### 1.11 Storage

- ⇒ Store the device, partially or fully assembled, in a dry and weatherproof manner in the original packaging in a clean environment.
- Protect the device against environmental effects and dirt until final installation.
- ⇒ We recommend storing the device for no longer than one year in order to guarantee trouble-free operation and the longest possible service life.
- ⇒ Even devices explicitly intended for outdoor use are to be stored as described prior to commissioning.
- ⇒ Maintain the storage temperature, see Chapter 3.5 Transport and storage conditions.
- ⇒ Make sure that all cable glands are fitted with dummy plugs.

### 1.12 Disposal

Comply with all relevant local requirements and regulations when disposing of the device.



ebmpapst

## Item no. 14569-5-9970 · ENU · Change 85321 · Approved 2015-12-09 · Page 2 / 10



## 2. INTENDED USE

The device is exclusively designed as a built-in device for conveying air according to its technical data.

Any other usage above and beyond this does not conform with the intended purpose and constitutes misuse of the device.

Customer equipment must be capable of withstanding the mechanical and thermal stresses that can arise from this product. This applies for the entire service life of the equipment in which this product is installed.

#### Intended use also includes

- conveying air at an ambient air pressure between 750 mbar and 1050 mbar.
- Using the device within the permitted ambient temperature range; see Chapter 3.5 Transport and storage conditions and Chapter 3.2 Nominal data.
- Operating the device with all protective devices.
- Following the operating instructions.

#### Improper use


In particular, operating the device in the following ways is prohibited and could be hazardous:

- Operating the device in an unbalanced state, e.g. due to dirt deposits or ice formation.
- Opening the terminal box during operation.
- Conveying air that contains abrasive particles.
- Conveying highly corrosive air, e.g. salt spray. Exception: devices designed for salt spray and correspondingly protected.
- Conveying air with high dust content, e.g. suctioning off sawdust.
- Operating the device close to flammable materials or components.
- Operating the device in an explosive atmosphere.
- Using the device as a safety component or to perform safety-related functions.
- Operation with completely or partially disassembled or manipulated protective devices.
- In addition, all applications not listed among the intended uses.



## 3. TECHNICAL DATA

## 3.1 Product drawing



#### All dimensions in mm.

1	Direction of air flow "V"
2	Tightening torque 0.5 ± 0.1 Nm
3	Cable diameter max. 7.5 mm, tightening torque 1.3 ± 0.2 Nm



### 3.2 Nominal data

Motor	M6E074-EI	
Phase	1~	1~
Nominal voltage / VAC	230	230
Frequency / Hz	50	60
Method of obtaining data	ml	ml
Valid for approval/ standard	CE	CE
Speed / min-1	750	700
Power consumption / W	125	150
Current draw / A	0.56	0.66
Capacitor / µF	3	3
Capacitor voltage / VDB	400	400
Capacitor standard	P0 (CE)	P0 (CE)
Max. back pressure / Pa	40	38
Min. ambient	-25	-25
temperature / °C		
Max. ambient	70	50
temperature / °C		
Starting current / A	0.68	0.68
Max. safe operating	1500	1500
speed / min <sup>-1</sup>	@ 70 °C	@ 70 °C

ml = Max. load  $\cdot$  me = Max. efficiency  $\cdot$  fa = Free air cs = Customer specification  $\cdot$  ce = Customer equipment

Subject to change

#### 3.3 Technical description

•		
Weight	6.1 kg	
Fan size	450 mm	
Rotor surface	Painted black	
Terminal box material	PC/ABS plastic	
Blade material	Press-fitted sheet steel blank, sprayed	
	with PP plastic	
Guard grille material	Steel, coated with black plastic (RAL	
	9005)	
Number of blades	5	
Airflow direction	"V"	
Direction of rotation	Counterclockwise, viewed toward rotor	
Degree of protection	IP44; installation- and position-dependent	
	as per EN 60034-5	
Insulation class	"F"	
Moisture (F) /	F1-2	
Environmental (H)		
protection class		
Installation position	Shaft horizontal or rotor on bottom; rotor	
	on top on request	
Condensation	On rotor side	
drainage holes		
Mode	S1	
Motor bearing	Ball bearing	
Touch current	< 0.75 mA	
according to IEC		
60990 (measuring		
circuit Fig. 4, TN		
system)		
Electrical hookup	Via terminal box, capacitor integrated and	
	connected	

Motor protection	Thermal overload protector (TOP) internally connected
with cable	Variable
Protection class	I (with customer connection of protective earth)
Motor capacitor according to EN 60252- 1 in safety protection class	P0/S0
Conformity with standards	EN 60335-1; CE
Approval	EAC



With regard to cyclic speed loads, note that the rotating parts of the device are designed for a maximum of one million load cycles. If you have special questions, consult ebm-papst for support.

### 3.4 Mounting data

⇒ Secure the screws against unintentional loosening (e.g. use selflocking screws).

Strength class of	8.8	
screws		

Any further mounting data required can be taken from the product drawing.

### 3.5 Transport and storage conditions

⇒ Use the device in accordance with its degree of protection.

Max. permitted ambient temp. for motor (transport/ storage)	+ 80 °C
Min. permitted ambient temp. for motor (transport/ storage)	- 40 °C



ebmpapst

## 4. CONNECTION AND STARTUP

#### 4.1 Mechanical connection



## CAUTION

Cutting and crushing hazard when removing fan from packaging

→ Carefully remove the device from its packaging, by the guard grille. Strictly avoid shocks.

- $\rightarrow$  Wear safety shoes and cut-resistant safety gloves.
- ⇒ Check the device for transport damage. Damaged devices are not to be installed.
- ⇒ Install the undamaged device in accordance with your application.



#### NOTE Motor capacitor

→ The product is equipped with a motor capacitor with safety protection class P0/S0 according to EN 60252-1. Take this into consideration when fitting it to the end product on the basis of applicable regulations.

### 4.2 Electrical connection



### DANGER Voltage on the device

Electric shock

- → Always connect a protective earth first.
- $\rightarrow$  Check the protective earth.



#### DANGER Faulty insulation

Risk of fatal injury from electric shock

- → Use only cables that meet the specified installation regulations for voltage, current, insulation material, capacity, etc.
- → Route cables so that they cannot be touched by any rotating parts.



## DANGER

Electrical charge (>50  $\mu$ C) between phase conductor and protective earth connection after switching off supply with multiple devices connected in parallel. Electric shock, risk of injury

→ Ensure sufficient protection against accidental contact. Before working on the electrical hookup, short the supply and PE connections.

### CAUTION

#### Voltage

The fan is a built-in component and has no disconnecting switch.

- $\rightarrow$  Only connect the fan to circuits that can be switched off with an all-pole disconnection switch.
- → When working on the fan, secure the system/machine in which the fan is installed so as to prevent it from being switched back on.

#### NOTE

#### Water ingress into wires or cables

Water ingress at the customer end of the cable can damage the device.

→ Make sure the end of the cable is connected in a dry environment.



Only connect the device to circuits that can be switched off with an all-pole disconnection switch.

## 4.2.1 Requirements

- ⇒ Check whether the data on the nameplate match the connection data and the data for the operating capacitor.
- ⇒ Before connecting the device, make sure the power supply matches the device voltage.
- Only use cables designed for the current level indicated on the nameplate.

For determining the cross-section, note the sizing criteria according to EN 61800-5-1. The protective earth must have a cross-section equal to or greater than that of the phase conductor.

We recommend the use of 105 °C cables. Ensure that the minimum cable cross-section is at least

AWG 26 / 0.13 mm<sup>2</sup>.

### Ground conductor contact resistance according to EN 60335

Compliance with the impedance specifications according to EN 60335 for the protective earth connection circuit must be verified in the end application.

Depending on the circumstances of installation, it may be necessary to connect an additional protective earth conductor to the extra protective earth terminal on the device.

## 4.2.2 Voltage control



With speed control using transformers or electronic voltage regulators (e.g. phase control), excessive current may occur. In addition, depending on how the device is installed, noises can occur with phase control.

### 4.2.3 Variable frequency drive

Please use a variable frequency drive only after consultation with ebmpapst.

When a variable frequency drive is used for speed adjustment, the maximum safe operating speed (see 3.2 Nominal data) may not be exceeded.



For operation with variable frequency drives, install sinusoidal filters that work on all poles (phase-phase and phase-ground) between the drive and the motor.

During operation with variable frequency drives, an all-pole sine filter protects the motor against high-voltage transients that can destroy the coil insulation system, and against harmful bearing currents.

Heating of the motor due to use of a variable frequency drive must be checked in the application by the customer.

## 4.3 Connection in terminal box

### 4.3.1 Preparing cables for connection


Only strip the cable as far as necessary, ensuring that the cable gland is sealed and there is no strain on the connections. For tightening torques, see Chapter 3.1 Product drawing.



Translation of the original operating instructions

## S6E450-AM13-50

## **Operating instructions**



### 4.3.2 Connecting wires to terminals

⇒ Remove the cap from the cable gland.

- Only remove caps where cables are fed in.
- ⇒ Route the wire(s) (not included in scope of delivery) into the terminal box.
- ⇒ First connect the "PE" (protective earth).

⇒ Connect the wires to the corresponding terminals.

Use a screwdriver to do so.

When connecting, ensure that no wire ends fan out.

⇒ Seal the terminal box.

#### 4.3.3 Cable routing

Water must be prevented from reaching the cable gland along the cable.

#### Fans installed lying flat

Make sure the cable is routed in a U-shaped loop.




Fig. 2: Fan installed lying flat, cable routed in a U-shaped loop.

### Fans installed upright

When routing the cable, make sure that the cable glands are located at the bottom. The cables must always be routed downward.





Fig. 3: Cable routing for fans installed upright.



## S6E450-AM13-50

# Operating instructions

## 4.4 Connection diagram



PE	green/yellow
L	black
Ν	blue



GREEN

Item no. 14569-5-9970 · ENU · Change 85321 · Approved 2015-12-09 · Page 8 / 10

### 4.5 Opening additional cable glands

A second cable gland opening can be made in the terminal box.

#### WARNING

In the event of a fault, the cable gland is energized Electric shock

 $\rightarrow$  Do not use metal cable glands with plastic terminal boxes.

- ⇒ Screw the cable gland into the precut thread using a wrench. When doing so, take note of the tightening torques; see Chapter 3.1 Product drawing.
- ⇒ Remove the plastic tab that fell off inside the terminal box when it was penetrated.



Fig. 4: Cable gland opening

### 4.6 Checking connections

- ⇒ Ensure isolation from supply (all phases).
- ⇒ Make sure a restart is impossible
- ⇒ Check the cables for proper fit.
- ⇒ Screw the terminal box cover back on again. Terminal box tightening torque, see Chapter 3.1 Product drawing.
- ⇒ Make sure the terminal box is completely closed and sealed and that all screws and cable glands have been properly tightened.

## 4.7 Switching on the device

The device may only be switched on if it has been installed properly and in accordance with its intended use, including the required safety mechanisms and professional electrical hookup. This also applies for devices which have already been equipped with plugs and terminals or similar connectors by the customer.



Hot motor housing

- Risk of fire
- → Ensure that no combustible or flammable materials are located close to the fan.
- ⇒ Before switching on, check the device for visible external damage and make sure the protective devices are functional.
- Check the fan's air flow paths for foreign matter and remove any foreign matter found.
- ⇒ Apply the nominal supply voltage.

## 4.8 Switching off the device

- ⇒ Disconnect the device from the power supply at the supply line's main switch.
- ⇒ When disconnecting, be sure to disconnect the ground connection last.

# 5. MAINTENANCE, MALFUNCTIONS, POSSIBLE CAUSES AND REMEDIES

Do not perform any repairs on your device. Send the device to ebmpapst for repair or replacement.

#### WARNING

Live terminals and connections even with device switched off

Electric shock

→ Wait five minutes after disconnecting the voltage at all poles before opening the device.

#### CAUTION

Electric charge on capacitor after device is switched off Electric shock, risk of injury

 $\rightarrow$  Discharge the capacitors before working on the device.

### CAUTION

The motor restarts automatically when operating voltage is applied, e.g. after a power failure. Risk of injury

- $\rightarrow$  Keep out of the device's danger zone.
- → When working on the device, switch off the line voltage and ensure that it cannot be switched back on.
- $\rightarrow$  Wait until the device comes to a stop.



If the device is out of use for some time, e.g. when in storage, we recommend switching it on for at least two hours to allow any condensation to evaporate and to move the bearings.

Malfunction/fault	Possible cause	Possible remedy
Impeller not	Imbalance in rotating	Clean the device;
running smoothly	parts	replace it if imbalance persists after cleaning. Make sure no weight clips are removed during cleaning.
Motor not turning	Mechanical blockage	Switch off, isolate from supply and remove mechanical blockage.
	Line voltage faulty	Check line voltage, restore power supply.
	Faulty connection	Isolate from supply, correct connection; see connection diagram.
	Thermal overload	Allow motor to cool
	protector activated	off, locate and rectify cause of error, release restart lockout if necessary
	Impermissible point of operation	Check point of operation
Motor overtemperature	Ambient temperature too high	Reduce ambient temperature if possible
÷	Deficient cooling	Improve cooling



ebm-papst Mulfingen GmbH & Co. KG · Bachmühle 2 · D-74673 Mulfingen · Phone +49 (0) 7938 81-0 · Fax +49 (0) 7938 81-110 · info1@de.ebmpapst.com · www.ebmpapst.com



In the event of further malfunctions, contact ebm-papst.

## 5.1 Cleaning

### NOTE

#### Damage to the device during cleaning Malfunction possible

→ Do not clean the device using a water jet or high-pressure cleaner.# Do not use any acid, alkali or solventbasedcleaning agents.# Do not use any pointed or sharpedged objects for cleaning

## 5.2 Safety inspection

What to check	How to check	How often	What action?
Contact protection cover for intactness or damage	Visual inspection	At least every 6 months	Repair or replacement of device
Device for damage to blades and housing	Visual inspection	At least every 6 months	Replacement of device
Fastening the cables	Visual inspection	At least every 6 months	Fasten
Fastening the protective earth terminal	Visual inspection	At least every 6 months	Fasten
Insulation of cables for damage	Visual inspection	At least every 6 months	Replace cables
Tightness of cable gland	Visual inspection	At least every 6 months	Retighten, replace if damaged
Condensation drainage holes for clogging, where necessary	Visual inspection	At least every 6 months	Open holes
Welds for crack formation	Visual inspection	At least every 6 months	Replace device

